

# SECURITY INCIDENT

Kenai Alt – Boys & Girls Club – Aurora Borealis Charter School

- Playground door propped open during Boys and Girls Club activity
- Adult male entered door from playground area and pulled fire alarm
- Perpetrator exited the building
- Alarm monitoring company alerted staff and called Fire Department
- Emergency services responded and determined it was a false alarm
- Emergency services encountered perpetrator during their sweep of grounds
- Films reviewed the next morning and perpetrator identified
- Films show perpetrator found to be loitering on site acting suspiciously
- Films show perpetrator was approached by B&G Club staff but remained on site
- Prompted by Emergency services, local law enforcement initiated an investigation

# SECURITY INCIDENT

## Sterling Elementary School

- Main entry door in view of the office is unlocked and open to the public
- Adult male entered main entry and pulled fire alarm and then exited
- School evacuated – Emergency Services responded and found no alarm
- Perpetrator loitered on site while students were in evacuation mode and tailgated the student body back to the building on re-entry
- School nurse recognized individual from prior association with family and realized he was out of place
- Nurse approached perpetrator who asked to use the bathroom
- Nurse isolated perpetrator in her office and kept occupied with small talk
- Admin immediately reviewed film and linked perpetrator to man with nurse
- Law enforcement called and perpetrator detained

# SECURITY INCIDENT

## Commonalities

- There was ready access to the building through an unsecured door  
BUILDING SECURITY
- Fire alarm pull station activated and then the perpetrator retreated  
FIRE ALARM PROTOCOL
- An unauthorized individual was on site and not challenged

# BUILDING SECURITY

WE NEED TO DO A BETTER JOB OF SECURING OUR BUILDINGS AGAINST UNAUTHORIZED ENTRY.

MOST BUILDINGS DO NOT HAVE LINE-OF-SIGHT CONTROL BETWEEN THE OFFICE AND FRONT DOOR.

FUNDING AVAILABILITY FOR BUILDING REMODELS ARE UNLIKELY.

IF WE WERE TO LOCK ALL EXTERIOR DOORS, HOW COULD WE DEAL WITH NEEDED ACCESS TO THE SCHOOL?

# BUILDING SECURITY

A PERMANENT SOLUTION CONSISTING OF  
REMODELING THE SCHOOL TO CONTAIN ACCESS TO  
THE SCHOOL AS PART OF THE ADMINISTRATIVE  
OFFICE WOULD BE THE BEST ALTERNATIVE

FUNDING FOR SUCH IS NOT IN CONSIDERATION


# BUILDING SECURITY

FOR AN INTERMEDIATE SOLUTION  
WE ARE LOOKING AT TWO OPTIONS FOR  
TWO DIFFERENT NEEDS:

A COMBO LOCK SYSTEM FOR STAFF


A “BUZZ ME IN” SYSTEM FOR THE PUBLIC

# BUILDING SECURITY




A CAMERA AND DOOR BELL IS INSTALLED ON ACCESS DOOR

# BUILDING SECURITY




WHEN AN INDIVIDUAL NEEDS ACCESS TO THE BUILDING

# BUILDING SECURITY




HE PUSHES THE DOOR BELL

# BUILDING SECURITY



THE DOOR BELL RINGS A PHONE IN THE OFFICE

# BUILDING SECURITY



THE CAMERA CAPTURES THE IMAGE OF WHO HAS RUNG THE DOORBELL

# BUILDING SECURITY



A STAFF MEMBER BRINGS UP THE CAMERA FEED

# BUILDING SECURITY



A CODE ENTERED INTO THE PHONE ACTIVATES AN ELECTRONIC DOOR LATCH

# BUILDING SECURITY

FOR AN IMMEDIATE – SHORT TERM NEED

IF WE WERE TO LOCK ALL EXTERIOR DOORS,  
STARTING IN 30 DAYS, HOW DO WE MANAGE THE  
ACCESS NEEDS TO OUR BUILDINGS?

STAFF/STUDENT?

PUBLIC?

# FIRE ALARM PROTOCOL

WHAT STEPS, IF ANY, DO YOU CURRENTLY FOLLOW  
WHEN A FIRE ALARM GOES OFF TO VERIFY ALARM  
IS BONA FIDE?

IS THERE A NEED TO CHANGE PROTOCOL?